



Regional Water Testing Laboratory,
(Uttar Pradesh Jal Nigam, Gorakhpur)

Address: EWS 388,389,390 Rapti Nagar Phase-I, Medical Road, Gorakhpur(U.P)-273003

BACTERIOLOGICAL SAMPLE TEST REPORT

Rept. No	410/Camp/Lab-1	Date:	21/06/2025	Page No	1/1
Customer Details					
Office Name and Address					
Ref Letter No & Date	14/06/2025				
Basic details of sample					
District	Gorakhpur	Block	--		
Gram Panchayat	--	Village	--		
Habitation	--	Location	Jagran Public School Campierganj, Gorakhpur		
Water Source	R.O	Sample Code	51644 (C/25/06/14)		
Quantity of Sample	500ml	Date of S.C.	14/06/2025		
Receiving Date	15/06/2025	S. Collector	Govind Kumar		
Sample Depositor	Govind Kumar				
Analysis Start Date	19/06/2025	Analysis Completion Date	20/06/2025		

Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH (25°C ± 2°C)	7.72		6.5-8.5	No relaxation	IS 3025 (Part 11):2017
2	Residual Chlorine	0	mg/L	0.2	1.0	IS 3025 (PART 26) : 1986
3	Total Coliform	0	CFU	0	CFU	APHA 23 rd Edition :2017
4	E.Coli	0	CFU	0	CFU	APHA 23 rd Edition :2017

Result : Satisfactory

Remark: Potable

Note 1. This Certificate refers only to the particular sample(s) submitted for testing.

- This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
- The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- Sample will be stored up to 7 days (in case of non-perishable items only) from the date of issue of tests reports unless.

Analysed By
Sandhya Verma

Authorized Signatory
Sandhya Verma

Laboratory Contact details: Email-labgorakhpur@gmail.com

Contact - +91 8604561988

End of the Report

Jagran Public School
Sandhya Verma
Principal

JAGRAN PUBLIC SCHOOL
Sandhya Verma
DIRECTOR